

## Certificate of Testing Microbiological Quality of Water

Site Id: C06560  
Myrddin Cwrt Cambria Cwrt &  
Naomi Cwrt (231)  
Llanelli  
Carmarthenshire  
Wales, SA15 2LJ  
SA15 2LJ

Date Sampled: 18-08-2016  
Date Received: 19-08-2016  
Date on Test: 19-08-2016

Our Ref: 95 - 2596521  
Lars: 243630

Client Id: TRI013  
Trinity Estates  
Vantage Point  
23 Mark Road  
Hemel Hempstead  
Hertfordshire

Sample Ref.	Source	Presumptive Coliforms MPN per 100ml	E. Coli MPN per 100ml	TVC (cfu/ml) 2 day @ 37C	TVC (cfu/ml) 3 day @ 22C
s985980	CWST 1 Naomi	<1	<1	21	1.5 x 10 <sup>3</sup>

The above sample(s) showed higher than expected Total Viable Counts.

We therefore recommend that the actions in the site written scheme are followed and a review of control measures is undertaken.

As a result of the review further action may be required such as regular flushing, increased monitoring or cleaning and disinfection of the affected area(s)



LEGIONELLA  
CONTROL ASSOCIATION  
REGISTRATION NUMBER: 1993/992

Clearwater Technology..... *T Laffey*

*Dr T Laffey, Technical Manager*

Sample number prefix 's' denotes testing performed by a sub-contracted UKAS accredited laboratory 0690  
Sampling opinions expressed herein are outside the scope of UKAS Accreditation.  
Tests marked \* in the report are not included in the UKAS Accreditation schedule.  
legionella results are a theoretical value calculated from 500ml sample (excluding uncertainty).

## Certificate of Testing for Legionella

This is to certify that the sample(s) submitted for specific testing has proved not to contain any detectable traces of Legionella pneumophila nor any other Legionella species

Site Id: C06560  
Myrddin Cwrt Cambria Cwrt &  
Naomi Cwrt (231)  
Llanelli  
Carmarthenshire  
Wales, SA15 2LJ  
SA15 2LJ

Date Sampled: 18-08-2016  
Date Received: 19-08-2016  
Date on Test: 19-08-2016

Our Ref: 95 - 2596521  
Lars: 243639

Client Id: TRI013  
Trinity Estates  
Vantage Point  
23 Mark Road  
Hemel Hempstead  
Hertfordshire

Sample Ref.	Source	Concentration cfu/1000ml	Serogroup
s986040	CWST 1 Myrddin	Not Detected <20	
s986041	CWST 2 Myrddin	Not Detected <20	
s986042	CWST 1 Naomi	Not Detected <20	
s986043	CWST 2 Naomi	Not Detected <20	
s986044	CWST 1 Cambria	Not Detected <20	
s986045	CWST 2 Cambria	Not Detected <20	



Clearwater Technology..... *T Laffey*

*Dr T Laffey, Technical Manager*

Sample number prefix 's' denotes testing performed by a sub-contracted UKAS accredited laboratory 0690  
Sampling opinions expressed herein are outside the scope of UKAS Accreditation.  
Tests marked \* in the report are not included in the UKAS Accreditation schedule.  
legionella results are a theoretical value calculated from 500ml sample (excluding uncertainty).