

Certificate of Testing for Legionella

This is to certify that the sample(s) submitted for specific testing has proved not to contain any detectable traces of Legionella pneumophila nor any other Legionella species

Site Id: C06560
 Myrddin Cwrt Cambria Cwrt &
 Naomi Cwrt (231)
 Llanelli
 Carmarthenshire
 Wales,

Date Sampled: 01-08-2017
 Date Received: 02-08-2017
 Date on Test: 02-08-2017

Our Ref: 93 - 3511471
 Lars: 271754

Client Id: TRI013
 Trinity Estates
 Vantage Point
 23 Mark Road
 Hemel Hempstead
 Hertfordshire

Sample Ref.	Source	Concentration cfu/1000ml	Concentration cfu/500ml group
s1079228	Station 1 Tank 1	Not Detected	Not Detected
s1079229	Station 2 Tank 2	Not Detected	Not Detected
s1079230	Station 3 T1082	Not Detected	Not Detected
s1079231	Station 3 T2082	Not Detected	Not Detected



Clearwater Technology.....


Dr T Laffey, Technical Manager

Sample number prefix 's' denotes testing performed by a sub-contracted UKAS accredited laboratory. 9658 Method AM067
 Sampling opinions expressed herein are outside the scope of UKAS Accreditation.
 Tests marked * in the report are not included in the UKAS Accreditation schedule.
 Legionella results are a theoretical value calculated from 500ml sample (excluding uncertainty).