

# Certificate of Testing

## Microbiological Quality of Water

Site Id: C06560  
 Myrddin Cwrt Cambria Cwrt &  
 Naomi Cwrt (231)  
 Llanelli  
 Carmarthenshire  
 Wales,

Date Sampled: 29-11-2017  
 Date Received: 30-11-2017  
 Date on Test: 30-11-2017

Our Ref: 93 - 3511471  
 Lars: 281715

Client Id: TRI013  
 Trinity Estates  
 Vantage Point  
 23 Mark Road  
 Hemel Hempstead  
 Hertfordshire

Sample Ref.	Source	Presumptive Coliforms MPN per 100ml	E. Coli MPN per 100ml	TVC (cfu/ml) 2 day @ 37C	TVC (cfu/ml) 3 day @ 22C
s1112897	CWST 1	<1	<1	<1	<1
s1112898	CWST 2	<1	<1	1	<1

Test results showed the above sample(s) to be satisfactory for the parameters tested.



**Clearwater Technology**.....  


*Dr T Laffey, Technical Manager*

Sample number prefix 's' denotes testing performed by a sub-contracted UKAS accredited laboratory. 9658  
 Sampling opinions expressed herein are outside the scope of UKAS Accreditation.  
 Tests marked \* in the report are not included in the UKAS Accreditation schedule.  
 Legionella results are a theoretical value calculated from 500ml sample (excluding uncertainty).