

Certificate of Testing

Microbiological Quality of Water

Site Id: C06560
 Myrddin Cwrt Cambria Cwrt &
 Naomi Cwrt (231)
 Llanelli
 Carmarthenshire
 Wales,

Date Sampled: 29-11-2017
 Date Received: 30-11-2017
 Date on Test: 30-11-2017

Our Ref: 93 - 3511471
 Lars: 281716

Client Id: TRI013
 Trinity Estates
 Vantage Point
 23 Mark Road
 Hemel Hempstead
 Hertfordshire

Sample Ref.	Source	Presumptive Coliforms MPN per 100ml	E. Coli MPN per 100ml	TVC (cfu/ml) 2 day @ 37C	TVC (cfu/ml) 3 day @ 22C
s1112899	CWST 1	<1	<1	<1	4
s1112900	CWST 2	<1	<1	<1	<1

Test results showed the above sample(s) to be satisfactory for the parameters tested.



Clearwater Technology.....


Dr T Laffey, Technical Manager

Sample number prefix 's' denotes testing performed by a sub-contracted UKAS accredited laboratory. 9658
 Sampling opinions expressed herein are outside the scope of UKAS Accreditation.
 Tests marked * in the report are not included in the UKAS Accreditation schedule.
 Legionella results are a theoretical value calculated from 500ml sample (excluding uncertainty).